

INFORME DE CALIDAD DEL AGUA
EMBOTELLADA 2026
Agua potable de emergencia "Mayday"

Nombre de Embotellador: Mayday Industries, Division of Ready America, Inc.

Dirección: 1399 Specialty Dr; Vista, CA 92081

Teléfono: 760-295-0234

Fuente(s): Distrito de Riego de Vista

Proceso de tratamiento: Filtración de carbono, Filtración de micras, Ósmosis inversa, Ozonización (desinfección)

DEFINICIONES:

- **Declaración de calidad:** Los estándares de calidad del agua embotellada proporcionan los límites legales máximos para una variedad de sustancias que están permitidas en el agua embotellada, junto con su monitoreo. Requisitos. Las sustancias incluyen contaminantes microbiológicos, pesticidas, contaminantes inorgánicos, contaminantes orgánicos, contaminantes radiológicos y otros. Los estándares han sido establecidos por la Administración de Alimentos y Medicamentos de los Estados Unidos (FDA), basados en los estándares públicos de agua potable de la Agencia de Protección Ambiental de los Estados Unidos (USEPA). CDPH adopta las regulaciones de la FDA pertinentes a los estándares de calidad del agua embotellada.
- **Nivel máximo de contaminante (MCL):** MCL es el nivel máximo de un contaminante permitido en el agua potable pública.
- **Normas primarias de agua potable (PDWS):** Las PDWS están establecidas para proporcionarla máxima protección factible a la salud pública. El objetivo de establecer PDWS es identificar los MCL, junto con sus requisitos de monitoreo y notificación, que previenen los efectos adversos para la salud. Los PDWS se establecen tan cerca del objetivo de salud pública (PHG) o son el objetivo de nivel máximo de contaminantes (MCLG) como es económica y tecnológicamente factible.
- **Objetivo de salud pública (PHG):** PHG es el nivel de un contaminante en el agua potable por debajo del cual no hay un riesgo conocido o esperado para la salud. Los PHG son establecidos por la Agencia de Protección Ambiental de California.

FUENTE DE AGUA:

Las fuentes de agua embotellada incluyen ríos, lagos, arroyos, estanques, embalses, manantiales y pozos. A medida que el agua viaja naturalmente sobre la superficie de la tierra o a través del suelo, puede recoger sustancias naturales, así como sustancias que están presentes debido a la actividad animal y humana. Las sustancias que pueden estar presentes en el agua de origen incluyen cualquiera de las siguientes:

- (1) Sustancias inorgánicas, incluidas, entre otras, sales y metales, que pueden ocurrir naturalmente o ser el resultado de la agricultura, la escorrentía de aguas pluviales urbanas, las descargas de aguas residuales industriales o domésticas, o la producción de petróleo y gas.
- (2) Pesticidas y herbicidas que pueden provenir de una variedad de fuentes, que incluyen, entre otras, la agricultura, la escorrentía de aguas pluviales urbanas y los usos residenciales.
- (3) Sustancias naturales que son subproductos de los procesos industriales y la producción de petróleo y también pueden provenir de estaciones de servicio, escorrentía de aguas pluviales urbanas, aplicaciones agrícolas y sistemas sépticos.
- (4) Organismos microbianos que pueden provenir de la vida silvestre, las operaciones agrícolas ganaderas, las plantas de tratamiento de aguas residuales y los sistemas sépticos.
- (5) Sustancias con propiedades radiactivas que pueden ser de origen natural o ser el resultado de la producción de petróleo y gas y de las actividades mineras".

CONTAMINANTES EN EL AGUA:

Se puede esperar razonablemente que el agua potable, incluyendo el agua embotellada, contenga al menos pequeñas cantidades de algunos contaminantes. La presencia de contaminantes no indica necesariamente que el agua represente un riesgo para la salud. Se puede obtener más información sobre los contaminantes y los posibles efectos en la salud llamando a la línea directa de la Administración de Alimentos y Medicamentos de los Estados Unidos, Food and Cosmetic (1-888-723-3366). Con el fin de garantizar que el agua embotellada sea segura para beber, la Administración de Alimentos y Medicamentos de los Estados Unidos y el Departamento de Salud Pública del Estado prescriben leyes y regulaciones que limitan la cantidad de ciertos contaminantes en el agua proporcionada por las compañías de agua embotellada.

Algunas personas pueden ser más vulnerables a los contaminantes en el agua potable que la población general. Personas inmunocomprometidas, incluidas, entre otras, personas con cáncer que se someten a quimioterapia, personas que se han sometido a trasplantes de órganos, personas con VIH / SIDA u otros trastornos del sistema inmunológico, algunos las personas mayores y los bebés pueden estar particularmente en riesgo de infecciones. Estas personas deben buscar asesoramiento sobre el agua potable de sus proveedores de atención médica. Las directrices de la Agencia de Protección Ambiental de los Estados Unidos y los Centros para el Control y la Prevención de Enfermedades sobre los medios apropiados para disminuir el riesgo de infección por criptosporidio y otros contaminantes microbianos están disponibles en la Línea Directa de Agua Potable Segura (1-800- 426-4791).

INFORMACIÓN SOBRE RETIRADAS DE PRODUCTOS:

Si desea saber si un producto de agua embotellada en particular ha sido retirado o está siendo retirado, visite el sitio web de la FDA <http://www.fda.gov/opacom/7alerts.html>.





ANALYTICAL REPORT

PREPARED FOR

Ready America
1399 Specialty Drive
Vista, California 92081

Generated 1/14/2026 11:39:27 AM

JOB DESCRIPTION

Bottled Lot No 11 - Title 21 + 50 State
Vista

JOB NUMBER

380-188518-1

Client Sample Results

Client: Ready America
Project/Site: Bottled Lot No 11 - Title 21 + 50 State

Job ID: 380-188518-1
SDG: Vista

Client Sample ID: Mayday Dec 2025 Lot No 11 (EXP. DEC 2030)

Lab Sample ID: 380-188518-1

Date Collected: 12/12/25 08:00

Matrix: Bottled Water

Date Received: 12/17/25 11:40

Method: EPA-DW 524.2 - Total Trihalomethanes

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Trihalomethanes, Total	3.2		0.50		ug/L			12/30/25 03:55	1

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<0.50		0.50		ug/L			12/30/25 03:55	1
1,1,1-Trichloroethane	<0.50		0.50		ug/L			12/30/25 03:55	1
1,1,2,2-Tetrachloroethane	<0.50		0.50		ug/L			12/30/25 03:55	1
1,1,2-Trichloroethane	<0.50		0.50		ug/L			12/30/25 03:55	1
1,1-Dichloroethylene	<0.50		0.50		ug/L			12/30/25 03:55	1
1,1-Dichloroethane	<0.50		0.50		ug/L			12/30/25 03:55	1
1,1-Dichloropropene	<0.50		0.50		ug/L			12/30/25 03:55	1
1,2,3-Trichlorobenzene	<0.50	^3+ *+	0.50		ug/L			12/30/25 03:55	1
1,2,3-Trichloropropane	<0.50		0.50		ug/L			12/30/25 03:55	1
1,2,4-Trichlorobenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
1,2,4-Trimethylbenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
1,2-Dichloroethane	<0.50		0.50		ug/L			12/30/25 03:55	1
1,2-Dichloropropane	<0.50		0.50		ug/L			12/30/25 03:55	1
1,3,5-Trimethylbenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
1,3-Dichloropropane	<0.50		0.50		ug/L			12/30/25 03:55	1
2,2-Dichloropropane	<0.50		0.50		ug/L			12/30/25 03:55	1
2-Butanone (MEK)	26		5.0		ug/L			01/06/26 16:53	1
Benzene	<0.50	*1	0.50		ug/L			12/30/25 03:55	1
Bromobenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
Bromochloromethane	<0.50		0.50		ug/L			12/30/25 03:55	1
Bromodichloromethane	1.3		0.50		ug/L			12/30/25 03:55	1
Bromoethane	<0.50		0.50		ug/L			12/30/25 03:55	1
Bromoform	<0.50		0.50		ug/L			12/30/25 03:55	1
Bromomethane (Methyl Bromide)	<0.50		0.50		ug/L			01/06/26 16:53	1
Carbon disulfide	<0.50		0.50		ug/L			12/30/25 03:55	1
Carbon tetrachloride	<0.50		0.50		ug/L			12/30/25 03:55	1
Chlorobenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
Chloroethane	<0.50		0.50		ug/L			12/30/25 03:55	1
Chloroform (Trichloromethane)	1.1		0.50		ug/L			12/30/25 03:55	1
Chloromethane (methyl chloride)	<0.50		0.50		ug/L			12/30/25 03:55	1
cis-1,2-Dichloroethylene	<0.50		0.50		ug/L			12/30/25 03:55	1
cis-1,3-Dichloropropene	<0.50		0.50		ug/L			12/30/25 03:55	1
Dibromochloromethane	0.82		0.50		ug/L			12/30/25 03:55	1
Dibromomethane	<0.50		0.50		ug/L			12/30/25 03:55	1
Dichlorodifluoromethane	<0.50		0.50		ug/L			12/30/25 03:55	1
Dichloromethane	<0.50		0.50		ug/L			12/30/25 03:55	1
Diisopropyl ether	<3.0		3.0		ug/L			12/30/25 03:55	1
Ethylbenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
Hexachlorobutadiene	<0.50	^3+	0.50		ug/L			12/30/25 03:55	1
Isopropylbenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
m,p-Xylenes	<0.50		0.50		ug/L			12/30/25 03:55	1
m-Dichlorobenzene (1,3-DCB)	<0.50		0.50		ug/L			12/30/25 03:55	1
Methyl-tert-butyl Ether (MTBE)	<0.50		0.50		ug/L			12/30/25 03:55	1
Naphthalene	<0.50		0.50		ug/L			12/30/25 03:55	1

Eurofins Pomona

Client Sample Results

Client: Ready America
Project/Site: Bottled Lot No 11 - Title 21 + 50 State

Job ID: 380-188518-1
SDG: Vista

Client Sample ID: Mayday Dec 2025 Lot No 11 (EXP. DEC 2030)

Lab Sample ID: 380-188518-1

Date Collected: 12/12/25 08:00

Matrix: Bottled Water

Date Received: 12/17/25 11:40

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
n-Butylbenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
N-Propylbenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
o-Chlorotoluene	<0.50		0.50		ug/L			12/30/25 03:55	1
o-Dichlorobenzene (1,2-DCB)	<0.50		0.50		ug/L			12/30/25 03:55	1
o-Xylene	<0.50		0.50		ug/L			12/30/25 03:55	1
p-Chlorotoluene	<0.50		0.50		ug/L			12/30/25 03:55	1
p-Dichlorobenzene (1,4-DCB)	<0.50		0.50		ug/L			12/30/25 03:55	1
p-Isopropyltoluene	<0.50		0.50		ug/L			12/30/25 03:55	1
sec-Butylbenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
Styrene	<0.50		0.50		ug/L			12/30/25 03:55	1
Tert-amyl methyl ether	<3.0		3.0		ug/L			12/30/25 03:55	1
Tert-butyl ethyl ether	<3.0		3.0		ug/L			12/30/25 03:55	1
tert-Butylbenzene	<0.50		0.50		ug/L			12/30/25 03:55	1
Tetrachloroethene (PCE)	<0.50		0.50		ug/L			12/30/25 03:55	1
Toluene	0.88		0.50		ug/L			12/30/25 03:55	1
trans-1,2-Dichloroethylene	<0.50		0.50		ug/L			12/30/25 03:55	1
trans-1,3-Dichloropropene	<0.50		0.50		ug/L			12/30/25 03:55	1
Trichloroethylene (TCE)	<0.50		0.50		ug/L			12/30/25 03:55	1
Trichlorofluoromethane (Freon 11)	<0.50		0.50		ug/L			12/30/25 03:55	1
Trichlorotrifluoroethane	<0.50		0.50		ug/L			12/30/25 03:55	1
Vinyl Chloride (VC)	<0.30		0.30		ug/L			12/30/25 03:55	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		70 - 130					12/30/25 03:55	1
1,2-Dichloroethane-d4 (Surr)	97		70 - 130					01/06/26 16:53	1
4-Bromofluorobenzene (Surr)	95		70 - 130					12/30/25 03:55	1
4-Bromofluorobenzene (Surr)	96		70 - 130					01/06/26 16:53	1
Toluene-d8 (Surr)	99		70 - 130					12/30/25 03:55	1
Toluene-d8 (Surr)	99		70 - 130					01/06/26 16:53	1

Method: EPA 522 - 1,4 Dioxane (GC/MS SIM)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,4-Dioxane	<0.069		0.069		ug/L		12/23/25 08:32	12/26/25 10:23	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,4-Dioxane-d8 (Surr)	97		70 - 130				12/23/25 08:32	12/26/25 10:23	1

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4'-DDD	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
2,4'-DDE	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
2,4'-DDT	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
2,4-Dinitrotoluene	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
2,6-Dinitrotoluene	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
4,4'-DDD	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
4,4'-DDE	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
4,4'-DDT	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Acenaphthene	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Acenaphthylene	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1

Eurofins Pomona

Client Sample Results

Client: Ready America
Project/Site: Bottled Lot No 11 - Title 21 + 50 State

Job ID: 380-188518-1
SDG: Vista

Client Sample ID: Mayday Dec 2025 Lot No 11 (EXP. DEC 2030)

Lab Sample ID: 380-188518-1

Date Collected: 12/12/25 08:00

Matrix: Bottled Water

Date Received: 12/17/25 11:40

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetochlor	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Alachlor (Alanex)	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Aldrin	<0.0096		0.0096		ug/L		01/02/26 08:24	01/04/26 11:56	1
alpha-BHC	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
alpha-Chlordane	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Anthracene	<0.019		0.019		ug/L		01/02/26 08:24	01/04/26 11:56	1
Atrazine	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Benz(a)anthracene	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Benzo[a]pyrene	<0.019		0.019		ug/L		01/02/26 08:24	01/04/26 11:56	1
Benzo[b]fluoranthene	<0.019		0.019		ug/L		01/02/26 08:24	01/04/26 11:56	1
Benzo[g,h,i]perylene	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Benzo[k]fluoranthene	<0.019		0.019		ug/L		01/02/26 08:24	01/04/26 11:56	1
beta-BHC	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Bis(2-ethylhexyl) phthalate	<0.58		0.58		ug/L		01/02/26 08:24	01/04/26 11:56	1
Bromacil	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Butachlor	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Butylbenzylphthalate	<0.48		0.48		ug/L		01/02/26 08:24	01/04/26 11:56	1
Caffeine	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Chlorobenzilate	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Chloroneb	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Chlorothalonil (Draconil, Bravo)	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Chlorpyrifos	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Chrysene	<0.019		0.019		ug/L		01/02/26 08:24	01/04/26 11:56	1
delta-BHC	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Di(2-ethylhexyl)adipate	<0.58		0.58		ug/L		01/02/26 08:24	01/04/26 11:56	1
Diazinon (Qualitative)	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Dibenz(a,h)anthracene	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Diclorvos (DDVP)	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Dieldrin	<0.0096		0.0096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Diethylphthalate	<0.48		0.48		ug/L		01/02/26 08:24	01/04/26 11:56	1
Dimethoate	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Dimethylphthalate	<0.48		0.48		ug/L		01/02/26 08:24	01/04/26 11:56	1
Di-n-butyl phthalate	<0.96		0.96		ug/L		01/02/26 08:24	01/04/26 11:56	1
Di-n-octyl phthalate	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Endosulfan I (Alpha)	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Endosulfan II (Beta)	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Endosulfan sulfate	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Endrin	<0.0096		0.0096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Endrin aldehyde	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
EPTC	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Fluoranthene	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Fluorene	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
gamma-Chlordane	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Heptachlor	<0.0096		0.0096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Heptachlor epoxide (isomer B)	<0.0096		0.0096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Hexachlorobenzene	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Hexachlorocyclopentadiene	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Indeno[1,2,3-cd]pyrene	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1

Eurofins Pomona

Client Sample Results

Client: Ready America
Project/Site: Bottled Lot No 11 - Title 21 + 50 State

Job ID: 380-188518-1
SDG: Vista

Client Sample ID: Mayday Dec 2025 Lot No 11 (EXP. DEC 2030)

Lab Sample ID: 380-188518-1

Date Collected: 12/12/25 08:00

Matrix: Bottled Water

Date Received: 12/17/25 11:40

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Isophorone	0.19		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Lindane	<0.0096		0.0096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Malathion	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Methoxychlor	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Metolachlor	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Metribuzin	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Molinate	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Naphthalene	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Parathion	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Pendimethalin (Penoxaline)	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Phenanthrene	<0.038		0.038		ug/L		01/02/26 08:24	01/04/26 11:56	1
Propachlor	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Pyrene	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Simazine	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Terbacil	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Terbutylazine	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Thiobencarb	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Total Permethrin (mixed isomers)	<0.19		0.19		ug/L		01/02/26 08:24	01/04/26 11:56	1
trans-Nonachlor	<0.048		0.048		ug/L		01/02/26 08:24	01/04/26 11:56	1
Trifluralin	<0.096		0.096		ug/L		01/02/26 08:24	01/04/26 11:56	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	97		70 - 130				01/02/26 08:24	01/04/26 11:56	1
Perylene-d12	57	S1-	70 - 130				01/02/26 08:24	01/04/26 11:56	1
Triphenylphosphate	136	S1+	70 - 130				01/02/26 08:24	01/04/26 11:56	1

Method: EPA 548.1 - Endothall (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Endothall	<5.0	^3+	5.0		ug/L		12/19/25 08:45	12/23/25 08:46	1

Method: EPA-DW2 504.1 - EDB, DBCP and 1,2,3-TCP (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,3-Trichloropropane	<0.020	^3+	0.020		ug/L		12/23/25 16:12	12/23/25 21:02	1
1,2-Dibromo-3-Chloropropane	<0.010		0.010		ug/L		12/23/25 16:12	12/23/25 21:02	1
1,2-Dibromoethane	<0.010		0.010		ug/L		12/23/25 16:12	12/23/25 21:02	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dibromopropane (Surr)	113		60 - 140				12/23/25 16:12	12/23/25 21:02	1

Method: EPA 505 - Organochlorine Pesticides/PCBs (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chlordane	<0.10		0.10		ug/L		12/23/25 11:50	12/23/25 15:55	1
PCB-1016	<0.071		0.071		ug/L		12/23/25 11:50	12/23/25 15:55	1
PCB-1221	<0.10		0.10		ug/L		12/23/25 11:50	12/23/25 15:55	1
PCB-1232	<0.10		0.10		ug/L		12/23/25 11:50	12/23/25 15:55	1
PCB-1242	<0.10		0.10		ug/L		12/23/25 11:50	12/23/25 15:55	1
PCB-1248	<0.10		0.10		ug/L		12/23/25 11:50	12/23/25 15:55	1
PCB-1254	<0.10		0.10		ug/L		12/23/25 11:50	12/23/25 15:55	1
PCB-1260	<0.071		0.071		ug/L		12/23/25 11:50	12/23/25 15:55	1

Eurofins Pomona

Client Sample Results

Client: Ready America
Project/Site: Bottled Lot No 11 - Title 21 + 50 State

Job ID: 380-188518-1
SDG: Vista

Client Sample ID: Mayday Dec 2025 Lot No 11 (EXP. DEC 2030)

Lab Sample ID: 380-188518-1

Date Collected: 12/12/25 08:00

Matrix: Bottled Water

Date Received: 12/17/25 11:40

Method: EPA 505 - Organochlorine Pesticides/PCBs (GC) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Polychlorinated biphenyls, Total	<0.10		0.10		ug/L		12/23/25 11:50	12/23/25 15:55	1
Toxaphene	<0.51		0.51		ug/L		12/23/25 11:50	12/23/25 15:55	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
Tetrachloro-m-xylene	109		70 - 130				12/23/25 11:50	12/23/25 15:55	1

Method: EPA-DW 515.4 - Herbicides (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4,5-T	<0.20		0.20		ug/L		12/19/25 06:10	12/19/25 18:12	1
2,4,5-TP (Silvex)	<0.10		0.10		ug/L		12/19/25 06:10	12/19/25 18:12	1
2,4-D	<0.10		0.10		ug/L		12/19/25 06:10	12/19/25 18:12	1
2,4-DB	<2.0		2.0		ug/L		12/19/25 06:10	12/19/25 18:12	1
3,5-Dichlorobenzoic acid	<0.50		0.50		ug/L		12/19/25 06:10	12/19/25 18:12	1
Acifluorfen	<0.20		0.20		ug/L		12/19/25 06:10	12/19/25 18:12	1
Bentazon	<0.50		0.50		ug/L		12/19/25 06:10	12/19/25 18:12	1
Dalapon	<1.0		1.0		ug/L		12/19/25 06:10	12/19/25 18:12	1
Dicamba	<0.10		0.10		ug/L		12/19/25 06:10	12/19/25 18:12	1
Dichlorprop	<0.50		0.50		ug/L		12/19/25 06:10	12/19/25 18:12	1
Dinoseb	<0.20		0.20		ug/L		12/19/25 06:10	12/19/25 18:12	1
Pentachlorophenol	<0.040		0.040		ug/L		12/19/25 06:10	12/19/25 18:12	1
Picloram	<0.10		0.10		ug/L		12/19/25 06:10	12/19/25 18:12	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
2,4-Dichlorophenylacetic acid (Surr)	114		70 - 130				12/19/25 06:10	12/19/25 18:12	1
2,4-Dichlorophenylacetic acid (Surr)	106		70 - 130				12/19/25 06:10	12/19/25 18:12	1

Method: SM 6251B - Haloacetic Acids (HAAs) (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromochloroacetic acid	<1.0		1.0		ug/L		12/19/25 09:05	12/19/25 18:32	1
Dibromoacetic acid	<1.0		1.0		ug/L		12/19/25 09:05	12/19/25 18:32	1
Dichloroacetic acid	<1.0		1.0		ug/L		12/19/25 09:05	12/19/25 18:32	1
Monobromoacetic acid	<1.0		1.0		ug/L		12/19/25 09:05	12/19/25 18:32	1
Monochloroacetic acid	<2.0		2.0		ug/L		12/19/25 09:05	12/19/25 18:32	1
Trichloroacetic acid	<1.0		1.0		ug/L		12/19/25 09:05	12/19/25 18:32	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
2,3-Dibromopropionic acid	104		70 - 130				12/19/25 09:05	12/19/25 18:32	1

Method: SM 6251B - Total Haloacetic Acids (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Haloacetic Acids 5	<2.0		2.0		ug/L			12/19/25 18:32	1

Method: EPA 218.7 - Chromium, Hexavalent (Ion Chromatography)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hexavalent Chromium (CrVI)	1.3		0.020		ug/L		12/23/25 10:47	12/23/25 12:32	1

Method: EPA 300.0 - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	1.8		0.50		mg/L			12/19/25 06:19	1
Chlorite	<10		10		ug/L			12/26/25 16:45	1

Eurofins Pomona

Client Sample Results

Client: Ready America
Project/Site: Bottled Lot No 11 - Title 21 + 50 State

Job ID: 380-188518-1
SDG: Vista

Client Sample ID: Mayday Dec 2025 Lot No 11 (EXP. DEC 2030)

Lab Sample ID: 380-188518-1

Date Collected: 12/12/25 08:00

Matrix: Bottled Water

Date Received: 12/17/25 11:40

Method: EPA 300.0 - Anions, Ion Chromatography (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Nitrate as N	0.45		0.050		mg/L			12/19/25 06:19	1
Bromide	<5.0		5.0		ug/L			12/26/25 16:45	1
Nitrite as N	<0.050		0.050		mg/L			12/19/25 06:19	1
Sulfate	<0.25		0.25		mg/L			12/19/25 06:19	1

Method: EPA 300.0 - Nitrogen, Nitrate-Nitrite

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Nitrate Nitrite as N	0.45		0.050		mg/L			12/19/25 06:19	1

Method: EPA 317 - Bromate, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromate	2.1		1.0		ug/L			12/27/25 00:24	1

Method: EPA 531.2 - Carbamate Pesticides (HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
3-Hydroxycarbofuran	<0.50		0.50		ug/L			12/19/25 02:00	1
Aldicarb	<0.50		0.50		ug/L			12/19/25 02:00	1
Aldicarb sulfone	<0.50		0.50		ug/L			12/19/25 02:00	1
Aldicarb sulfoxide	<0.50		0.50		ug/L			12/19/25 02:00	1
Baygon	<0.50		0.50		ug/L			12/19/25 02:00	1
Carbaryl	<0.50		0.50		ug/L			12/19/25 02:00	1
Carbofuran	<0.50		0.50		ug/L			12/19/25 02:00	1
Methiocarb	<0.50		0.50		ug/L			12/19/25 02:00	1
Methomyl	<0.50		0.50		ug/L			12/19/25 02:00	1
Oxamyl	<0.50		0.50		ug/L			12/19/25 02:00	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
BDMC	94		70 - 130		12/19/25 02:00	1

Method: EPA 547 - Glyphosate (DAI HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Glyphosate	<6.0		6.0		ug/L			12/23/25 05:36	1

Method: EPA 549.2 - Diquat and Paraquat (HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Diquat	<0.41		0.41		ug/L		12/18/25 12:03	12/19/25 17:48	1

Method: EPA 331.0 - Perchlorate (LC/MS/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perchlorate	<0.50		0.50		ug/L			12/30/25 06:50	1

Method: EPA 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosfluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1

Eurofins Pomona

Client Sample Results

Client: Ready America
Project/Site: Bottled Lot No 11 - Title 21 + 50 State

Job ID: 380-188518-1
SDG: Vista

Client Sample ID: Mayday Dec 2025 Lot No 11 (EXP. DEC 2030)

Lab Sample ID: 380-188518-1

Date Collected: 12/12/25 08:00

Matrix: Bottled Water

Date Received: 12/17/25 11:40

Method: EPA 537.1 - Perfluorinated Alkyl Acids (LC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorononanoic acid (PFNA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0		ng/L		12/22/25 03:37	12/23/25 03:15	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	114		70 - 130	12/22/25 03:37	12/23/25 03:15	1
13C2 PFHxA	108		70 - 130	12/22/25 03:37	12/23/25 03:15	1
13C3-GenX	108		70 - 130	12/22/25 03:37	12/23/25 03:15	1
d5-NEtFOSAA	117		70 - 130	12/22/25 03:37	12/23/25 03:15	1

Method: EPA 1613B - Tetra Chlorinated Dioxin (GC/MS/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,3,7,8-TCDD	<4.8		4.8		pg/L		12/18/25 06:08	12/19/25 16:55	1
<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>				<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C-2,3,7,8-TCDD	76		31 - 137				12/18/25 06:08	12/19/25 16:55	1

Method: EPA 200.7 - Metals (ICP)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	0.25		0.050		mg/L			12/26/25 11:55	1
Calcium	<0.10		0.10		mg/L			12/26/25 11:55	1
Iron	<0.010		0.010		mg/L			12/26/25 11:55	1
Magnesium	<0.10		0.10		mg/L			12/26/25 11:55	1
Potassium	<0.20		0.20		mg/L			12/26/25 11:55	1
Sodium	2.6		0.10		mg/L			12/26/25 11:55	1

Method: EPA 200.8 - Mercury (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hg	<0.20		0.20		ug/L			12/26/25 12:08	1

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Aluminum	<20		20		ug/L			12/26/25 12:08	1
Antimony	<1.0		1.0		ug/L			12/26/25 12:08	1
Arsenic	<1.0		1.0		ug/L			12/26/25 12:08	1
Barium	<2.0		2.0		ug/L			12/26/25 12:08	1
Beryllium	<0.30		0.30		ug/L			12/26/25 12:08	1
Cadmium	<0.50		0.50		ug/L			12/26/25 12:08	1

Eurofins Pomona

Client Sample Results

Client: Ready America
Project/Site: Bottled Lot No 11 - Title 21 + 50 State

Job ID: 380-188518-1
SDG: Vista

Client Sample ID: Mayday Dec 2025 Lot No 11 (EXP. DEC 2030)

Lab Sample ID: 380-188518-1

Date Collected: 12/12/25 08:00

Matrix: Bottled Water

Date Received: 12/17/25 11:40

Method: EPA 200.8 - Metals (ICP/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chromium	1.5		0.90		ug/L			12/26/25 12:08	1
Copper	1.0		1.0		ug/L			12/26/25 12:08	1
Lead	<0.50		0.50		ug/L			12/26/25 12:08	1
Manganese	<2.0		2.0		ug/L			12/26/25 12:08	1
Nickel	<5.0		5.0		ug/L			12/26/25 12:08	1
Selenium	<2.0		2.0		ug/L			12/26/25 12:08	1
Silver	<0.50		0.50		ug/L			12/26/25 12:08	1
Thallium	<0.30		0.30		ug/L			12/26/25 12:08	1
Uranium	<1.0		1.0		ug/L			12/26/25 12:08	1
Zinc	<5.0		5.0		ug/L			12/26/25 12:08	1
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Uranium	<0.67		0.67		pCi/L			12/26/25 12:08	1

Method: SM 2340B - Total Hardness (as CaCO3) by calculation

Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hardness (as CaCO3)	<2.9		2.9		mg/L			12/28/25 19:47	1
Calcium hardness as CaCO3	<2.5		2.5		mg/L			12/28/25 19:47	1
Magnesium hardness as calcium carbonate	<0.41		0.41		mg/L			12/28/25 19:47	1

General Chemistry

Analyte	Result	Qualifier	NONE	NONE	Unit	D	Prepared	Analyzed	Dil Fac
Langelier Index (SM 2330B)	-8				LangSU			12/18/25 12:35	1
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Turbidity (EPA 180.1)	0.65		0.10		NTU			12/18/25 18:27	1
Phenols, Total (EPA 420.4)	<1.0		1.0		ug/L			12/26/25 21:11	1
Cyanide (SM 4500 CN F)	<0.025		0.025		mg/L			12/27/25 09:56	1
Alkalinity as CaCO3 (SM 2320B)	<4.0		4.0		mg/L			12/18/25 14:04	1
Bicarbonate Alkalinity as CaCO3 (SM 2320B)	<4.0		4.0		mg/L			12/18/25 14:04	1
Carbonate Alkalinity as CaCO3 (SM 2320B)	<4.0		4.0		mg/L			12/18/25 14:04	1
Hydroxide Alkalinity as CaCO3 (SM 2320B)	<4.0		4.0		mg/L			12/18/25 14:04	1
Specific Conductance (SM 2510B)	14		2.0		umhos/cm			12/18/25 14:04	1
Total Dissolved Solids (SM 2540C)	<10		10		mg/L			12/23/25 14:31	1
Chlorine, Total Residual (SM 4500 Cl G)	<0.050		0.050		mg/L			12/31/25 12:52	1
Chloramines, Total (SM 4500 Cl G)	<0.050		0.050		mg/L			12/31/25 12:52	1
Chlorine, free (SM 4500 Cl G)	<0.050		0.050		mg/L			12/31/25 12:52	1
Fluoride (SM 4500 F C)	<0.050		0.050		mg/L			12/19/25 19:20	1
Methylene Blue Active Substances (SM 5540C)	<0.10		0.10		mg/L			12/27/25 12:50	1
Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac
Chlorine dioxide (SM 4500 ClO2 D)	<0.24		0.24		mg/L			12/31/25 12:52	1
Color, Apparent (SM 2120B)	<2.0		2.0		Color Units			12/18/25 17:42	1
Odor (SM 2150B)	1.0		1.0		T.O.N.			12/18/25 11:29	1
pH (SM 4500 H+ B)	6.0		0.01		SU			12/18/25 14:04	1

Eurofins Pomona

Client Sample Results

Client: Ready America
Project/Site: Bottled Lot No 11 - Title 21 + 50 State

Job ID: 380-188518-1
SDG: Vista

Client Sample ID: Mayday Dec 2025 Lot No 11 (EXP. DEC 2030)

Lab Sample ID: 380-188518-1

Date Collected: 12/12/25 08:00

Matrix: Bottled Water

Date Received: 12/17/25 11:40

Method: EPA 900.0 - Gross Alpha and Gross Beta Radioactivity

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Gross Alpha	0.0704	U	0.601	0.601	3.00	0.682	pCi/L	12/31/25 09:18	01/03/26 10:34	1
Gross Beta	0.351	U	0.497	0.498	4.00	0.499	pCi/L	12/31/25 09:18	01/03/26 10:34	1

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.0106	U	0.161	0.161	1.00	0.201	pCi/L	12/30/25 08:35	01/03/26 10:29	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	67.9		30 - 110					12/30/25 08:35	01/03/26 10:29	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.444		0.410	0.412	1.00	0.396	pCi/L	12/30/25 08:22	01/05/26 09:50	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	81.6		30 - 110					12/30/25 08:22	01/05/26 09:50	1
Y Carrier	77.8		30 - 110					12/30/25 08:22	01/05/26 09:50	1

Method: TAL-STL Ra226_Ra228 Pos - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	0.455		0.440	0.442	5.00	0.396	pCi/L		01/08/26 10:37	1

Method: SM7500_Rn_B - Radon

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radon 222	23.6		8.85		50.0	8.51	pCi/L	12/18/25 16:30	12/19/25 09:31	1

Method: SM 9215B - Heterotrophic Plate Count

Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac
Heterotrophic Plate Count	<1		1		CFU/mL			12/19/25 17:11	1

Method: SM 9223B - Coliforms, Total, and E.Coli (Colilert - Quanti Tray)

Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac
Coliform, Total	<1.0		1.0		MPN/100mL			12/19/25 18:03	1
E. Coli	<1.0		1.0		MPN/100mL			12/19/25 18:03	1

Eurofins Pomona